



CITY OF ALTAMONTE SPRINGS

Public Works Site Inspection

Project Name: _____ Permit No. _____

Project Location: _____

Phase V: TRASH AND RECYCLING COLLECTION FACILITIES - 5005

GENERAL RULES:

- Code References for Trash and Recycling Collection Facilities: Site Plan Regulations - Section 4.3.3.1.1(j), Required submittals for final site plan; Design Standards - Section 6.1.15, Solid waste collection areas.
- Standard Details Reference: MI-008, Dumpster Pad and Enclosure.
- Other References: Frequently Asked Questions - Trash and Recycling Collection Area Enclosure Maintenance.
- Per BFS D P-P 08-03, dumpster pads without a footing shall only require inspection by the Engineering Site Inspector. A BFS D Inspector can inspect the pad in place of the Engineering Inspector if the BFS D Inspector gets assigned the inspection. Dumpster pads with a footing shall require an inspection by a BFS D Inspector for structural components.

		Pass	Fail	NA
1.	Trash collection (i.e., dumpster or can) enclosures indicated on the site plan provided and are constructed per the site plan (i.e., location and orientation are correct). Enclosures are not to be located within a required landscape buffer.			
2.	If enclosure is masonry, verify exterior has been finished as indicated on the site plan or landscape plan. All masonry walls must be finished (Exposed or painted masonry block is not allowed. Exposed or painted brick or split-face block is allowed).			
3.	Lockable 180-degree swing gates installed - verify gates are not chain link, which is prohibited.			
4.	Enclosure contains bollards per the standard detail.			
5.	Enclosure six feet in height, minimum eight feet long, and minimum fifteen feet wide.			
6.	Concrete apron constructed at entrance to enclosure per the standard detail and site plan.			
7.	Any obstructions to the overhead lifting of the dumpster by the truck, such as landscaping or electrical wires.			
8.	Recycling containers located within an enclosure.			

Inspection Date: _____

COMMENTS:

Site Representative Signature

Engineering Inspector Signature