



# CITY OF ALTAMONTE SPRINGS

## Public Works Site Inspection

Project Name: \_\_\_\_\_ Permit No. \_\_\_\_\_

Project Location: \_\_\_\_\_

**Phase V: PARKING SPACES/SIGNING & MARKINGS - 5025**

**GENERAL RULES:**

- Code References for Parking Space/Signing & Markings: Zoning Regulations - Division 41, Off-street Parking, Loading.
- Standard Detail References: MI001, Typical Parking Lot Layout; MI002, Typical Fire Lane Requirements; MI-003, Accessible Parking Spaces; MI-004, Accessible Parking – Single Space Striping; MI-005, Accessible Parking – Multiple Space Striping; MI006, Accessible Parking – Pavement Symbol; MI-007, Reserved Parking Signage; MI007-xB – Van Accessible Parking Signage.
- Other References: Frequently Asked Questions – Parking Lot Maintenance.

		Pass	Fail	NA
<b>Parking Spaces:</b>				
1.	Parking lot stripes six inches wide, FDOT rated paint, white.			
2.	Standard parking spaces are 9 feet wide x 20 feet deep. Spaces may be 18 feet deep if front of space overhangs landscape area.			
3.	Wheelstops provided as indicated on site plan.			
4.	Any special signs or markings indicated on the site plan provided on the site.			
5.	Drive aisle widths consistent with site plan. Corner radii consistent with site plan.			
6.	Landscape island widths and locations consistent with site plan. Landscape islands min. 5' wide of pervious area (i.e., min. 5' from back-of-curb to back-of-curb).			
7.	Compact parking spaces indicated with signs or pavement markings as per the site plan. Min. 8' wide x 16' deep.			
8.	Number of compact parking spaces consistent with site plan.			
<b>Disabled Parking Spaces:</b>				
9.	Number of disabled parking spaces provided is consistent with the number of spaces indicated on the site plan.			
10.	Disabled spaces are 12 feet wide x 20 feet deep. Spaces may be 18 feet deep if front of space overhangs landscape area.			
11.	Wheelchair ramp minimum of five feet wide.			
12.	Design, pavement stripes and markings, and signs for disable spaces consistent with City standard details located in the site plan.			
13.	Disabled parking sign includes "\$100.00 Fine City Code 24-26."			

